Engineering System Integrity Electrical Network Safety Rules

Engineering Specification Electrical Distribution Unit

One Method of Safe Working

SP D 79039
Electrical Tools and Test
Equipment

Version 1.5

Date in Force: 1 November 2022



Approved Associate Director Authorised by: Electrical Distribution Unit by: Publications Manager System Integrity System Integrity

Disclaimer

This document was prepared for use by persons in connection with works near or on/within the rail network electricity system operated by Sydney Trains. Sydney Trains makes no warranties, express or implied, that compliance with the contents of this document shall be sufficient to ensure safe systems or work or operation. It is the document user's sole responsibility to ensure that the copy of the document it is viewing is the current version of the document as in use by Sydney Trains. To the extent permitted by law, Sydney Trains excludes any and all liability for any loss or damage, however caused (including through negligence), which may be directly or indirectly suffered in connection with the use of this document.

Copyright

The information in this document is protected by copyright and no part of this document may be reproduced, altered, stored, or transmitted by any person without the prior consent of Sydney Trains.

Document control

Version	Date	Author/ Prin. Eng.	Summary of change
1.0	10 September 2020	Nick Loveday	First issue
1.1	25 September 2020	Nick Loveday	Detailed procedure for operating the Hivotech OHW Tester inserted
1.2	1 February 2020	Nick Loveday	Revised approved 11 - 66kV HV Testers
1.3	17 February 2020	Nick Loveday	Revised approved HV Testers at 5.1-5.3
1.4	1 February 2022	ENSR Project Team	Reviewed as part of the ENSR Project.
1.5	1 November 2022	Wayne Halls	Remove detail procedure for hivotech. Reference to SWI's hivotech, catu775 Catu CM46 Range. Emphasised special insulated apparatus, not accessories. Update LV non-contact detectors. Update HV and insulated sticks.

Summary of changes from previous version

Summary of change	Section
Addition of substantiation documentation location (RM8) added throughout doc	4
Reference documentation removal of duplicated information	5.1
Reference documentation Hivotech use transferred to SWI and removed	6.3
Limitations added	6.7
LV non-contact testers updated	6.8
Special Insulated apparatus – amalgamation of insulated tools and rope insulators. Accessories removed from doc	7
Requirements expanded to include a summary of requirements of EP15000001SP and IEC61243-1 for non-linear loads with Auto-reclose enabled	7.1
Catu CM46 Range added	7.4
Altered to generic to suit spec A-842	7.5
Altered for emphasis on line rope insulators	

Table of Contents

1	Introduction	4
2	Definitions	4
3	Scope	4
4	Information	4
5	Portable Connections	5
5.1	1500 Volt portable rail connection	5
5.2	HVAC overhead line star-connected earthing equipment	6
5.3	HVAC overhead line series-connected earthing equipment	6
6	Test equipment	7
6.1	TAPLIN D225/M 11kV – 132kV High Voltage Tester	
6.2	11kV – 66kV High Voltage Detectors	8
6.3	Hivotech 1500V DC OHW tester	9
6.4	1500 Volt DC rail clamp	9
6.5	1500V DC Substation Testers	11
6.6	LR tester	12
6.7	OHW structure-to-rail voltage test kit	13
6.8	Low Voltage Non-Contact Detectors	14
6.9	Phase-test lamps	15
6.10	Multimeter – phase identification	15
7	Specially Insulated Apparatus	16
7.1	HV insulated stick	16
7.2	Round measuring telescopic stick	17
7.3	Operating stick – dense foam filled	17
7.4	OHW/Rail connection insulated sticks	18
7.5	1500 Volt DC insulated stick – foam filled	19
7.6	1500 Volt DC operating and measuring telescopic sticks	
7.7	Live line rope insulator	20
8	Assemblies and Kits	22
8.1	Live low-voltage rescue kit	22
8.2	Pole-top rescue kit	23
8.3	Pole marker	23
8.4	Substation demarcation taping equipment	24
8.5	1500 Volt OHW Attached Climbing Kit Assembly	25
9	Reference documents	26

1 Introduction

This document describes the tools and test equipment approved by Sydney Trains per *GL D 79106 Selection and Approval of Tools and Test Equipment* for use by persons holding an electrical authorisation in accordance with *PR D 78701 Personnel Certifications – Electrical* when performing electrical work on low-voltage, 1500 Volt DC or high voltage equipment.

2 Definitions

Refer to the **Electrical Safety Definitions** page available on the **RailSafe** site.

3 Scope

Where the Electricity Network Safety Rules require approved equipment to be used, that means an item nominated in this specification.

Where the Electricity Network Safety Rules do not require approved equipment to be used, an authorised person may choose commercially available equipment suitable for the task.

Equipment that loses approval status will be removed from this document.

4 Information

The following information is provided:

Equipment Name – the short name of the item.

Make & Model – the original equipment manufacturer (OEM) and model number, including the version (if relevant).

Source(s) – the preferred supplier of the equipment (if not the OEM).

Applications – its intended purpose(s).

Documentation – List of the available documentation such assembly, instructions,


SWMS and SWIs etc.

RM8 Document storage location.

Limitations – any constraints or known issues with the use of the equipment.

5 Portable Connections

5.1 1500 Volt portable rail connection



The 1500 Volt portable rail connection equipment consists of an OHW connection clamp, a rail clamp and approximately 12m of 120mm² flexible insulated cable for connection between the two clamps.

The cable and clamps are used in conjunction with a 4m fibreglass two-piece stick fitted with a bayonet socket for attachment and detachment of the OHW connection clamp to the stick. The OHW connection clamp is a screw type, operated by rotating the insulated stick.

A second OHW connection clamp may be connected to the first by a short length of 120mm² insulated cable to allow two sections of overhead wiring over the same track to be rail connected via the one rail clamp. Two sets of fibreglass sticks will be required.




Portable Rail Connecting Clamp

5.2 HVAC overhead line star-connected earthing equipment

Equipment Name	HVAC Overhead Line Star Connected Earthing Equipment
Make & Model	Thew & McCann
Source(s)	TMAC
Application	For making a temporary connection between high-voltage equipment and earth
Documentation	EL0027468 and SP D 79047 Earthing High Voltage Equipment using Portable Earthing Equipment Appendix B Overhead Line Star Connected Earthing Equipment
	SP D 79033 Requirements for Portable Earthing Equipment for the High Voltage System
Limitations	-

5.3 HVAC overhead line series-connected earthing equipment




6 Test equipment


6.1 TAPLIN D225/M 11kV – 132kV High Voltage Tester



Equipment Name	11kV – 132kV High Voltage Tester
Make & Model	ABB TAPLIN D225/M
Source(s)	GTR Electrics (Gary Rogers) - No longer Available
Application	Testing for live HV equipment.
Documentation	DSYD2022/61355 D225/M Electronic HV Line Tester- Operators Instructions
	PR D 78203 High Voltage Operating Procedure
	FSYD2022/6404 High Voltage AC Tester ABB D225/M
Limitations	-

6.2 11kV – 66kV High Voltage Detectors






6.3 Hivotech 1500V DC OHW tester



6.4 1500 Volt DC rail clamp





Equipment Name	1500V DC rail clamp (screw)
Make & Model	Thew & McCann Type No. 360 628 002
Source(s)	Pfisterer, TMAC
Application	Provides a temporary connection to a rail.
Documentation	PR D 78305 1500 Volt Operating Procedures
	The cable used to attach above clamps onto the LR Tester is specified as follows:
	Cable type – 25 mm², Olex Versolex HD s/c power/welding cable, 0.6/1kV, flexible XLPE insulated and TPE sheathed to AS/NZS 5000.1 and AS/NZS 1995, preferably with the clear and transparent cable sheath.
	Cable lug – 25 mm², Utilux copper crimp lugs, M12 stud size, Catalogue No. H1416B/50, Tooling #20 38-77CU.
	Cable length -sufficient length to allow the use of the LR Tester from ground level and suitable for easy storage.
Limitations	-

6.5 1500V DC Substation Testers



Equipment Name	1500 Volt DC Substation Tester
Make & Model	DEHN
Source(s)	IPD
Application	For testing 1500 Volt equipment inside substations
Documentation	DSYD2022/78734 DEHN 1500V DC Substation Tester – Operators Instructions
	PR D 78305 1500 Volt Operating Procedures
	FSYD2022/6457 1500V Substation Tester - DEHN
Limitations	-



Equipment Name	Substation 1500 Volt DC 2-Pole
Make & Model	Hollow Tube Conduit (HTC) Tester
Source(s)	PTC - Not Available
Application	For testing 1500V equipment inside substations
Documentation	PR D 78305 1500 Volt Operating Procedures
	FSYD2022/6458 DC Substation Tester - HTC
Limitations	

6.6 LR tester




Equipment Name	Line to Rail (LR) Tester
Make & Model	PTC -
Source(s)	PTC - Not Available
Application	Continuity testing of rail-connecting cables at 1500 Volt field switches.
Documentation	PR D 78305 1500 Volt Operating Procedures
Limitations	Not to be used for testing dead


6.7 OHW structure-to-rail voltage test kit



Equipment Name	OHW structure to rail voltage test kit
Make & Model	Kit comprised of:
	Fluke series 170 digital multimeter
	2. Fluke C70Y yellow holster
	3. Fluke 80K-6 high voltage probe (earth lead lengthened to 5m)
	4. 5m extension earth lead
	5. Rail clip with 300mm earth lead tail
	300mm earth lead tail with 10mm termination eye for attachment to rail vehicles
	7. An uncontrolled copy of PR D 78306
	8. 9 Volt Battery (Eveready No. 216 6F22 or similar)
	Plastic tool box for storage of the test equipment.
Source(s)	Fluke where indicated, and commercially available suppliers.
Application	
Documentation	PR D 78306 1500 Volt DC Overhead Wiring Structure to Rail Voltage Test
Limitations	_

6.8 Low Voltage Non-Contact Detectors





6.9 Phase-test lamps

Equipment Name	Various
Make & Model	Various
Source(s)	Commercially available – e.g. TMAC, TEN Group, etc. Noncontact types are preferred.
Application	Phase identification of 3-phase low voltage services.
Documentation	PR D 78402 Work on the Low Voltage Distribution System
Limitations	_

6.10 Multimeter – phase identification


Equipment Name	Various
Make & Model	Various
Source(s)	Commercially available – e.g. Blackwoods, Rexel, etc.
Application	Phase identification of 3-phase low voltage services.
Documentation	PR D 78402 Work on the Low Voltage Distribution System
Limitations	_

7 Specially Insulated Apparatus

Specially insulated apparatus per the ENSRs provide the safety medium to ensure the operator does not encroach the SAD.

Accessories for the tools shall be risk assessed for suitability for the task by the operator and therefore do not require inclusion in this document

7.1 HV insulated stick



HV insulated sticks shall have a solid or foam-filled insulating element.

The insulating element may be of multiple portions to a length (Li), to suit the required 3 phase system voltage, conductive portions excluded.

The length of the insulating element is indicated by a Red Limit Mark.


Note: When the Limit Mark is absent, the limit shall be at the extent of the insulating element.

System Voltage	Insulating Element (Li)
<u><</u> 66 kV	830mm
132 kV	1700mm


The assembled insulating stick shall be of a length, which ensures that a minimum distance of 1500mm is achieved between the Limit Mark and the Hand Guard (multiple sections allowed).

The Hand Guard to base shall be >700mm.


7.2 Round measuring telescopic stick




7.3 Operating stick – dense foam filled




7.4 OHW/Rail connection insulated sticks






7.5 1500 Volt DC insulated stick – foam filled




7.6 1500 Volt DC operating and measuring telescopic sticks



7.7 Live line rope insulator



Equipment Name	Live line rope accessory with composite insulator
Make & Model	
Source(s)	Cutting Head from Hastings FTG 453/17 (S/C: 001874239, EL015095) from W560 Clyde Warehouse (Distributed by DULHUNTY POWER (AUST) PTY LTD). Rope pulley arrangement assembled by Network Base personnel.
Application	Electrically insulated tools and equipment for use near or on/within LIVE 1500 Volt equipment.
Documentation	D2015/47063 Use of Electrically Insulated Tools and Equipment On, Near or in the Vicinity of LIVE 1500V DC equipment Rope pull type cutter with composite insulator fitting No 453/17, drawing No EL0150595 installed within the rope 1.4 metres from the insulated tool accessory. NOTE: The operator is to ensure that the rope below the insulator is to remain outside the required SAD (0.5M for Authorised Persons)
Limitations	_



8 Assemblies and Kits

8.1 Live low-voltage rescue kit



Equipment Name	Live Low-voltage Rescue Kit, comprising of:	
	• torch	
	emergency isolation tag	
	low voltage retrieval aid (insulated crook)	
	trauma dressing	
	rescue kit bag	
	fire blanket	
	insulated gloves	
	list of contents for kit.	
Make & Model	NA	
Source(s)	TMAC and other suppliers	
Application		
Documentation	SP D 79032 Live Low Voltage Rescue Kit	
	D2013/80870 Rescue from Live Low Voltage - Including Rescue Kit Care)	
Limitations	_	

8.2 Pole-top rescue kit




Equipment Name	Pole Top Rescue Kit
Make & Model	
Source(s)	Commercially available – e.g. TMAC, TEN Group, Balmoral Engineering, Safety Supply Solutions etc.
Application	
Documentation	PR D 78109 Pole Top Rescue SP D 79040 Pole Top Rescue Kits
Limitations	
Limitations	-Only to be used for rescue

8.3 Pole marker




8.4 Substation demarcation taping equipment



Equipment Name	Substation Electrically Safe Work Area Demarcation Taping Equipment
Make & Model	
Source(s)	Refer to TfNSW specification for supplier details.
Application	For substation use: tape, tape stands, warning sign holder, tape stand weights, entrance bollards, warning signs.
Documentation	TfNSW standard T HR EL 15001 SP Substation Electrically Safe Work Area Demarcation Taping Equipment PR D 78506 Substation – Demarcation Taping
Limitations	_

8.5 1500 Volt OHW Attached Climbing Kit Assembly



9 Reference documents

D2013/80532 Using 1500V Overhead Wiring Attached Climbing Ladder

D2013/80533 Working from 1500V Overhead Wiring Attached Climbing Ladder

D2013/80870 Rescue from Live Low Voltage - Including Rescue Kit Care)

D2015/47063 Use of Electrically Insulated Tools and Equipment On, Near or in the Vicinity of LIVE 1500V DC equipment

D2022/4477 Use of Approved High Voltage AC Contact Voltage Detectors – CATU CC775

D2022/4012 Hivotech 1500V DC OHW Tester application and functions

EP 15 00 00 01 SP High Voltage AC Voltage Detector (Nominal Voltage of 11kV - 66kV)

EP 15 10 00 03 SP 1500V OHW Attached Climbing Kit Assembly

PR D 78108 Pre-work Hazard Assessment for Work on Poles with Live Exposed Equipment

PR D 78109 Pole Top Rescue

PR D 78203 High Voltage Operating Procedure

PR D 78305 1500 Volt Operating Procedures

PR D 78306 1500 Volt DC Overhead Wiring Structure to Rail Voltage Test

PR D 78402 Work on the Low Voltage Distribution System

PR D 78506 Substation - Demarcation Taping

PR D 78701 Personnel Certifications – Electrical

SP E 79030 Voltage Detector for use on 1500V DC Overhead Wiring

SP D 79032 Live Low Voltage Rescue Kit

SP D 79033 Requirements for Portable Earthing Equipment for the High Voltage System

SP D 79045 Inspection and Care of Portable Rail Connecting Equipment for 1500 Volt Overhead Wiring

SP D 79047 Earthing High Voltage Equipment using Portable Earthing Equipment

T HR EL 15001 SP Substation Electrically Safe Work Area Demarcation Taping Equipment

IEC 61243-1 Live Working-Voltage Detectors Pt1