

Pre-work Pole Hazard Assessment

Work Location: _____ Pole Number: _____

| Number circuits 1 to 6 from top down. Include street lighting as a separate circuit. | CIRCUIT | | | | | |
|--|--|----------|------|------|------|-------|
| | 1 | 2 | 3 | 4 | 5 | 6 |
| Voltage | | | | | | |
| Owner / operator | | | | | | |
| Feeder number (high voltage) | | | | | | |
| Conductors <i>damaged</i> or <i>down</i> | | | | | | |
| <i>Alive, dead, or earthed</i> | | | | | | |
| Safe Approach Distance (m) (Refer below for mandated distances) | | | | | | |
| Safe Approach Distances visualised and related to <i>landmarks</i> ? [Y/N] | | | | | | |
| Is the work above this circuit? [Y/N] | | | | | | |
| Is the work on this circuit? [Y/N] | | | | | | |
| Will workers climb through or past this circuit to work on other circuits? [Y/N] | | | | | | |
| Are live low voltage conductors spaced far enough apart to safely climb through? [Y/N/NA] | | | | | | |
| Will conductive equipment or conductors have to be raised or lowered through this circuit? [Y/N] | | | | | | |
| Other electrical pole hazards? [Y/N] | | | | | | |
| Permit number (if circuit is dead) | | | | | | |
| Has permanent insulation on the conductors been inspected? [Y/N/NA] | | | | | | |
| Is temporary LV cable cover required to be installed on low voltage conductors? [R/Y/N/NA] | | | | | | |
| Has the condition of this and adjacent poles and ties been checked? [Y/N] | | | | | | |
| Is it necessary to place a pole marker above this circuit? [Y/N] | | | | | | |
| Have any exposed earths been pointed out to all persons who will work on the pole? [Y/N] | | | | | | |
| Is a pole top rescue kit open and ready for use at the base of the pole? [Y/N/NA] | Have workers put on the required PPE (including working gloves)? [Y/N] | | | | | |
| Can the work be done safely without persons or tools infringing the SAD's? [Y/N] | | | | | | |
| Voltage | 240/415V | 2.2-11kV | 22kV | 33kV | 66kV | 132kV |
| Safe Approach Distance (SAD) for authorised persons | 0.5m | 0.7m | 1.0m | 1.0m | 1.0m | 1.5m |

Legend

R: Required

Y: Yes

N: No

N/A: Not Applicable

Completed by: _____
Print _____ Signature _____ Time hours on ____/____/20____
Date

Checked by: _____
Print _____ Signature _____ Time hours on ____/____/20____
Date

Work party: _____
Signature _____ Signature _____ Signature _____ Signature

This form must be used prior to work on poles supporting live exposed conductors or equipment. Refer to PR D 78108 for detailed instruction on how to use and complete this form.