

**Engineering System Integrity
Electrical Network Safety Rules**

**Engineering Procedure
Electrical Distribution Unit**

Working Near or On/Within

PR D 78403

**Work on Live Low Voltage
Equipment**

Version 1.2

Date in Force: 1 February 2022

Approved by: Associate Director
Electrical Distribution Unit
Engineering System Integrity

Authorised by: Engineering Technical
Publications Manager
System Integrity

Disclaimer

This document was prepared for use by persons in connection with works near or on/within the rail network electricity system operated by Sydney Trains. Sydney Trains makes no warranties, express or implied, that compliance with the contents of this document shall be sufficient to ensure safe systems or work or operation. It is the document user's sole responsibility to ensure that the copy of the document it is viewing is the current version of the document as in use by Sydney Trains. To the extent permitted by law, Sydney Trains excludes any and all liability for any loss or damage, however caused (including through negligence), which may be directly or indirectly suffered in connection with the use of this document.

Copyright

The information in this document is protected by copyright and no part of this document may be reproduced, altered, stored or transmitted by any person without the prior consent of Sydney Trains.

Document control

Version	Date	Author/ Prin. Eng.	Summary of change
1.0	18 May 2016	Chris Leung	First issue as a Sydney Trains document, rebranded from previous RailCorp SMS-06-EN-0590 V1.2
1.1	20 February 2019	Nick Loveday	Updated PR D 78403 "Approved by" to Associate Director Electrical Distribution Unit.
1.2	1 February 2022	ENSR Project Team	Reviewed as part of the ENSR Project.

Summary of changes from previous version

Summary of change	Section
Minor grammatical updates	All
Updated reference documents	All

Table of Contents

1	Purpose and scope	4
2	Definitions	4
3	Legislation	4
3.1	Electrical Installation	4
3.2	Workplace Health and Safety	4
3.3	Work on Live LV Equipment (including Installations).....	5
4	Hazards relating to live work	5
5	Hazard controls for work near or on/within exposed energised LV equipment, including installations	6
5.1	Planning	6
5.2	Personnel and competence	6
5.3	Tools, equipment and personal protective equipment	7
5.4	Preparation for incident response	7
5.5	Organisation of work area	7
5.6	Work methods	7
6	Working on live Low Voltage (LV) aerial lines	8
6.1	Personnel	8
6.2	Preparation.....	8
6.3	Conditions for work	8
6.4	Passing between conductors	9
6.5	Insulation	9
6.6	Application and removal of temporary covers on LV conductors	9
7	Working on live Low Voltage (LV) equipment or installations	10
8	Reference documents	10

1 Purpose and scope

This document describes the procedures to be followed whilst carrying out work on live low voltage (LV) equipment, including LV electrical installations. The scope of this document includes climbing through exposed LV aerial mains to work above.

2 Definitions

Refer to the **Electrical Safety Definitions** page available on the **RailSafe** site.

3 Legislation

In accordance with *Work Health and Safety Regulation 2017 (NSW)* work must not commence on energised electrical equipment.

Furthermore supply shall be removed before work is to be performed which involves:

- a. The connection between the main neutral and the earthing system being removed, or
- b. A neutral conductor, which is carrying load current, becoming discontinuous.

If work involves the earth conductor becoming discontinuous, for a portion of the installation, supply shall be removed from that portion of the installation.

3.1 Electrical Installation

An electrical installation is specifically defined in Part 1 of the *Gas and Electrical (Consumer Safety) Act 2017*. Within the rail electrical system, a low voltage electrical installation is any fixed low voltage wiring and equipment used for the conveyance, control, and use of electricity within a particular location.

The 1500 Volt DC rail traction system, rail signalling system, and high voltage installations are not classed as electrical installations.

3.2 Workplace Health and Safety

The *Work Health and Safety Act 2011 (NSW)* and *Work Health and Safety Regulation 2017 (NSW)* place specific risk control obligations upon owners and controllers of premises, properties, and establishments concerning the practice of working near or on/within energised electrical installations. In particular, where such owners/controllers engage the services of electrical workers, then it cannot be expected or required that the electrical worker(s) carry out work on installations that are energised. The owner/controller shall either ensure that the work can be carried out following the de-energisation of the installation, or, where it is necessary in the interests of health and safety (e.g. life-saving equipment) that the electrical work is carried out while the installation is energised, a full risk assessment is carried out by a person(s) appropriately qualified to do so. Refer to *PR D 78701 Personnel Certifications – Electrical*.

Further guidance on the workplace health and safety obligations for work on energised installations is provided in Clauses 147 to 161 of the *Work Health and Safety Regulation 2017 (NSW)*.

3.3 Work on Live LV Equipment (including Installations)

As defined in the *Electricity Supply Act 1995 (NSW)*, Sydney Trains is a network operator (i.e. an electricity distributor/supply authority). Division 4 of the *Workplace Health and Safety Regulation 2017 (NSW)* describes the requirements for carrying out work on energised electrical equipment. Clause 152 of this Regulation outlines that Division 4 is not applicable to a supply authority working on equipment controlled or operated by the authority to generate, transform, transmit or supply electricity.

Therefore live work on Sydney Trains' LV electrical equipment for the distribution of electricity is allowed provided that the associated hazards are identified and controlled to ensure that it is safe to do so.

Work on live LV installations is permitted, subject to compliance with Clause 157 of the *Work Health and Safety Regulation 2017 (NSW)*, as described in Section 3.2 above. More details on this aspect are addressed in Section 7 of this document.

4 Hazards relating to live work

Persons working near or on/within energised exposed LV electrical equipment or installations should be aware that a fault current may be many times the rated current for short times during fault conditions. If a fault current occurs, severe burns and flash burns to the face, eyes or other parts of the body are likely.

Full information regarding foreseeable hazards and effect is outlined in *PR D 78108 Pre-work Hazard Assessment and Controls for Work on Poles with Live Exposed Equipment*.

5 Hazard controls for work near or on/within exposed energised LV equipment, including installations

Work under isolated condition is always the first option to be considered. Work on live LV equipment or installation should only be considered if it is necessary to do so in the interests of safety and the risk of harm would be greater if the circuits and apparatus were de-energised before work. Refer to *SMS-07-GD-3084 Hazard Identification and Safety Risk Assessment* for Sydney Trains hierarchy of control.

5.1 Planning

Before commencing work on exposed energised LV equipment/conductors, a written assessment of the associated risks shall be made in consultation with the persons proposing to do the work. Refer to *SMS-06-OP-3043 Preparing and using Safe Work Practices* which details how to prepare Safe Work Method Statements (SWMS) or Safe Work Instructions (SWI).

The work has been approved by the Senior Manager Electrical Engineering or a delegated Electrical Authorised Person.

The work is carried out in accordance with a Safe Work Method Statement for the work. Generally the Safe Work Method Statement should stipulate not less than two layers of control against each hazard identified. For example:

- a. contact with live parts – insulated tools (1st level of control) and insulating gloves (2nd level of control)
- b. flash – temporary shrouds over earthed metal (1st level of control), and flash resistant clothing and eye/face protection (2nd level of control).

5.2 Personnel and competence

The persons doing the work shall be appropriately qualified, trained and instructed in safe working practices for the particular task, including the proper use of test equipment, tools, accessories and personal protective equipment.

The only exception to this is a person undergoing training who may be permitted to undertake work on live LV electrical equipment provided that person has been assessed to be competent to perform similar work under dead conditions.

The person doing the work is under the direct/constant supervision of another person who is competent in:

- a. The particular task being undertaken, and
- b. Releasing a person from live LV electrical equipment, and
- c. Cardio-pulmonary resuscitation (CPR).

5.3 Tools, equipment and personal protective equipment

Appropriate test equipment, tools and accessories, provided to the persons doing the work, shall be properly used, well maintained, and shall be inspected or checked to be in sound serviceable conditions prior to use.

Appropriate clothing and personal protective equipment (PPE) shall be properly worn and used by the persons doing the work. The appropriate Sydney Trains issued PPE shall be used unless the risk assessment indicates otherwise. For more information on PPE refer to *D2013/80874 PPE for Electrical Work*.

Appropriate Arc Rated PPE shall include but is not limited to:

- a. Flame-retardant/flash resistant clothing including long trousers, and a long sleeve shirt buttoned close to the neck and at the wrist.
- b. Insulating gloves (compliant and used in accordance with *AS/NZS IEC 60903:2020 Live working - Electrical insulating gloves*).
- c. Over-gloves to protect the insulating gloves from cuts abrasions and heat.
- d. Suitable footwear.
- e. Eye and face protection.

Portable ladders with metal or metal reinforced stiles shall not be used for work near or on/within live LV equipment or installations.

5.4 Preparation for incident response

The LV Rescue Kit shall be available and ready for immediate use at the work sites as described in *D2013/80870 Rescue from Live Low Voltage (Including Rescue Kit Care)*.

The isolation point of the relevant electrical supply has been clearly identified and is able to be reached and operated quickly without any need to negotiate or remove obstacles.

5.5 Organisation of work area

The work area shall be clear of obstructions to enable an unhindered entry and exit. Unauthorised persons shall be prevented from entering the work area by the use of signage, barriers, or both. All work on energised conductors shall be done from ground level or a stable work platform approved for that use.

5.6 Work methods

Precautions shall be taken, or procedures put in place, to prevent the possibility of simultaneous contact with conductors at different voltages. Connections should be neither made nor broken under load.

6 Working on live Low Voltage (LV) aerial lines

In addition to the preceding sections, the following sections apply to work on aerial lines which form part of a:

- a. LV distribution system, or
- b. LV installation.

6.1 Personnel

All work on LV aerial lines shall be carried out by an Authorised Overhead Traction Worker or a Qualified Electrician who is also an Authorised Overhead Worker (refer to PR D 78701). In addition, the person doing the work is attended by another person who shall also be competent in rescuing a person from a pole, structure or elevating work platform. In the case of live work, a safety observer who is competent to perform the live work, and in releasing a person from live LV electrical apparatus, shall be present.

6.2 Preparation

Prior to work commencing, a Pre-Work Hazard Assessment shall be carried out in accordance with PR D 78108 and D2013/80874.

When work is carried out aloft on live LV equipment using a ladder or elevating work platform, a rescue kit shall be placed open and ready for immediate use, at the base of each pole or structure. Prior to commencing work, a visual check of the kit shall be made to ensure that all items are present and that the rescue rope is clipped to the rescue strap. Check also that the rescue rope grab device is attached to the safety rope, if it is used for attached climbing.

All insulating covers, mats, etc. shall be thoroughly checked to be in good order prior to commencing work.

6.3 Conditions for work

A person shall not work on live LV exposed aerial lines unless:

- a. The conductors have been identified as LV, and
- b. The work is carried out in accordance with an approved live LV work procedure, and
- c. A clearance of 0.5m is maintained from any exposed LV conductor, except the one being worked on, and from any earthed metal, and
- d. Suitable insulating material (refer to Section 6.5 below), barriers or covers are used to prevent inadvertent contact with other live exposed conductors or earth, and
- e. The work can be completed in accordance with Section 6.4 below.

NOTE

With regard to telecommunications cables (Pay TV, telephone, etc). The carrier wire, fittings and pole attachments are connected to the local distributor's LV neutral and are to be treated as an earthed neutral conductor. In some cases telecommunications carriers have used 'king bolts' and the protruding end of the bolt is also to be treated as an earthed neutral.

6.4 Passing between conductors

A person is not permitted to pass between the conductors of live LV aerial lines at any point, where they are spaced less than 1.2m apart, unless the conductors are:

- a. Permanently insulated (refer Section 6.5 below), or
- b. Temporarily covered with suitable insulating material (refer Section 6.6).

The minimum distance for (a) and (b) above is of 1.0m in each direction from the point nearest to the person's body on each conductor.

6.5 Insulation

Care shall be taken to check that the insulation of permanently insulated conductors is in good condition and that there are no exposed connections on the conductor within the work area. In addition to the initial inspection, conducted as part of the Hazard Assessment, ongoing attention shall be given to this issue during the course of the work. Approved insulating covers and lengths of split insulating hose are provided to temporarily cover conductors. The work supervisor shall ensure that insulating covers are available, are in good condition and are used in the correct manner.

6.6 Application and removal of temporary covers on LV conductors

The following procedure applies to the application, utilisation and removal of temporary covers:

- a. Prior to application, the temporary covers shall be inspected by an Authorised Person (Mains) (refer to the **Electrical Safety Definitions** page available on the **RailSafe** site) to ensure the integrity of their insulation properties. If there is any doubt about the insulation properties, put aside for testing and use other temporary covers in good condition.
- b. The person applying or removing the temporary covers shall wear insulated gloves on both hands.
- c. Temporary covers shall be applied on one conductor at any time.
- d. Temporary covers are to be corrected immediately it is detected that the temporary cover has moved or been damaged.
- e. When used in conjunction with mobile plant, shall extend a minimum of 5m beyond the extremities of where the mobile plant will be operating.
- f. Care shall be exercised to ensure that no part of the body shall come within the minimum Safe Approach Distance of 0.5m from any conductor, except for hands wearing insulation gloves.
- g. On completion of the work, only one temporary cover shall be removed at any one time.

7 Working on live Low Voltage (LV) equipment or installations

Work may only be carried out live when the work can be performed safely and either:

- a. It is necessary to leave supply on to facilitate testing or fault finding, or
- b. The removal of supply will cause other safety risks.

Where authorised electrical workers are working live on a LV installation, the requirements of *D2013/80873 Work on Low Voltage Installations* and the *WorkCover NSW Code of Practice for Low Voltage Electrical Work* shall be followed.

Work can only be carried out on LV equipment/installation under live conditions by persons trained and authorised to work live as per PR D 78701 with hazard controls as per Section 5 in this document.

8 Reference documents

AS/NZS IEC 60903:2020 Live working - Electrical insulating gloves

D2013/80870 Rescue from Live Low Voltage (Including Rescue Kit Care)

D2013/80873 Work on Low Voltage Installations

D2013/80874 PPE for Electrical Work

Electricity Supply Act 1995 (NSW)

PR D 78108 Pre-work Hazard Assessment and Controls for Work on Poles with Live Exposed Equipment

PR D 78701 Personnel Certifications – Electrical

SMS-06-OP-3043 Preparing and using Safe Work Practices

SMS-07-GD-3084 Hazard Identification and Safety Risk Assessment

Work Health and Safety Act 2011 (NSW)

Work Health and Safety Regulation 2017 (NSW)

WorkCover NSW Code of Practice for Low Voltage Electrical Work