

<b><u>Inspection Record Sheet</u></b>		
<b>Portable Earthing Set for mains/substation <sup>(1)</sup></b>		
<b>Equipment Unique Identification Number</b>		<b>Copper/Aluminium Cable <sup>(2)</sup></b>

Note (1): Select 'mains' or 'substation' as required. Insert name of substation at the right box for SS use.

Note (2) Select 'Copper' or 'Aluminium' as required. If Aluminium cable, re-termination must be performed every 6 years and recorded under the 'Comments' column below.

The six-monthly and three-yearly inspections are to be undertaken respectively in accordance with Sections 4.3 and 4.4 of *PR D 78205 Inspection and Care of Portable Earthing Equipment for the High Voltage System*.

Inspection Interval	Date of inspection	Inspected by (Name) and/or (Company)	Result (Tick as appropriate)		Comments (eg reason for fail)
			Pass	Fail	
6-monthly					
6-monthly					
6-monthly					
6-monthly					
6-monthly					
3-yearly					
6-monthly					
6-monthly					
6-monthly					
6-monthly					
6-monthly					
3-yearly					
6-monthly					
6-monthly					
6-monthly					
6-monthly					
6-monthly					
3-yearly					
6-monthly					
6-monthly					
6-monthly					
6-monthly					
6-monthly					
3-yearly					